

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7270-1288:166

Page 1 of 1

**CATEGORY:** Heat Detector

**LISTEE:** Gamewell, 12 Clintonville Rd, Northford CT 06472-1653  
Contact: Brian Reynolds (203) 484-6124 FAX (203) 484-7309

**DESIGN:** Models SS-T, SS-TR, and SS-TH fixed temperature electronic heat detectors. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** 135<sup>0</sup> F fixed temperature for Models SS-T and SS-TR  
190<sup>0</sup> F fixed temperature for Model SS-TH

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical ratings, and UL label.

**APPROVAL:** Listed as heat detectors for use with separately listed Notifier Models B501 or B710LP bases (CSFM Listing No. 7300-0028:173) and listee's separately listed compatible fire alarm control units. Refer to listee's Installation Instruction Manual for details.

**XLF:** 7279-0028:196

07-08-2004



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JULY 8, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy  
Program Manager**